



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • <http://www.cti.org>

July 1, 2017
(Revision 3)

Liang Chi Industry Company, Ltd.
No. 1, Sec. 3, Nan King East Road
Taipei, Taiwan, R.O.C.

Subject: CTI Cooling Tower Certification
Liang Chi Industry Company, Ltd.
R-LC Line of Cross-flow, Induced-draft Cooling Towers

Greetings:

The Liang Chi Industry Company, Ltd. line of R-LC cross-flow, induced-draft cooling towers, as described in your original application and subsequent revisions through June 19, 2017, has satisfactorily fulfilled the requirements for certification of thermal performance by the Cooling Technology Institute (CTI), as set forth in the CTI Certification Standard STD-201(15). A listing of the twenty-two (22) models included in the CTI Certified R-LC line is attached for reference.

The R-LC line of cross-flow, induced-draft cooling towers has been assigned and should begin to use CTI Certification Validation Number C11E-11R03 (originally 11-20-05) and you are hereby authorized and encouraged to display the CTI Certification Logo in all pertinent literature and are required to affix the CTI Certification Label on all towers comprising the line, as provided in the Certification Standard.

This CTI Certification requires the successful completion of a CTI Annual Reverification Test to remain in effect in subsequent years.

Very truly yours,

Michael G. Womack, PE
CTI Thermal Certification Administrator



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Liang Chi Industry Company, Ltd.
R-LC Line of CTI Certified Cross-flow, Induced-draft Cooling Towers
CTI Certification Validation Number C11E-11R03
July 1, 2017 (Revision 3)

R-LC-01004	R-LC-10025
R-LC-01005	R-LC-10030
R-LC-01006	R-LC-10035
R-LC-01007	R-LC-15040
R-LC-02008	R-LC-15045
R-LC-02010	R-LC-15050
R-LC-05012	R-LC-20060
R-LC-05015	R-LC-20070
R-LC-07017	R-LC-30080
R-LC-07020	R-LC-30090
R-LC-07022	R-LC-40100

See Footnotes, Next Page



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Liang Chi Industry Company, Ltd.
R-LC Line of CTI Certified Cross-flow, Induced-draft Cooling Towers
CTI Certification Validation Number C11E-11R03
July 1, 2017 (Revision 3)

Footnotes:

1. Multiple cell configurations of the single cell models above are also available but not listed individually. Multi-cell configurations are end-wall to end-wall arrangements of the single cell designs which do not impact the air flow rate or capacity of the individual cells, and are included in the certification.
2. Sample Model Number for multiple cell model :
R-LC-05012-C3 where :
R-LC = Product Line Designator
-05012 = Model Number
-C = Cell
3 = Number of Cells (When the number is 1, it stands for the single-cell tower, so R-LC-05012-C1 and R-LC-05012 are identical single-cell towers.)
3. Certification includes the optional Stainless Steel components that do not affect thermal capacity in addition to standard Hot Dip Galvanized Steel components.
4. Certification includes optional Stainless Steel and Hot Dip Galvanized Steel piping components that do not affect thermal capacity in addition to standard PVC piping components.
5. Certification includes optional gear and belt reducers that do not affect thermal capacity in addition to standard belt reducers.
6. Certification includes optional internal piping arrangements that are not affect thermal capacity in addition to standard external piping arrangements.
7. Certification includes optional Stainless Steel and Hot Dip Galvanized Steel fan stacks, casings and water basins/sumps that do not affect thermal capacity, in addition to the standard FRP fan stacks, casings and water basins/sumps.
8. Certification includes optional items that do not affect thermal capacity, such as access ladder, handrails, maintenance platform and walkway, etc.